

**EXHIBIT “1” – NOTICE OF VIOLATION**  
Effluent Limit Violations

| Violation Date | Monitoring Period | Monitoring Location | Violation Type | Parameter | Reported Value | Permit Limit | Units | Pollutant Category | % Exceeded | Serious / Chronic | Water Code Section 13385 | Penalty |
|----------------|-------------------|---------------------|----------------|-----------|----------------|--------------|-------|--------------------|------------|-------------------|--------------------------|---------|
| 12/23/24       | 4th Quarter 2024  | M-001               | Daily Maximum  | MBAS      | 1              | 0.5          | mg/l  | 1                  | 100%       | Serious           | (h)1                     | \$3,000 |

**Total:        \$3,000**